

**SANTA YNEZ COMMUNITY SERVICES DISTRICT
BOARD OF DIRECTORS**

**SPECIAL MEETING
February 28, 2017
2:00 P.M.
1070 Faraday, Santa Ynez, CA**

AGENDA

1. CALL TO ORDER
2. ROLL CALL
3. PLEDGE OF ALLEGIANCE
4. PUBLIC COMMENTS: Members of the public may address the Board on any items of interest within the subject matter and jurisdiction of the Board but not on its agenda today. (Government Code - § 54954.2)
5. AUTHORIZE STAFF TO SPEND MONEY NOT TO EXCEED \$20,000.00 TO REPAIR THE BROKEN SEWER LINE AT THE INTERSECTION OF CIMARRON AND REMMINGTON.
6. ADJOURNMENT

Persons with disabilities who require any disability-related modification or accommodation, including auxiliary aids or services, in order to participate in the meeting are asked to contact the District's Board Secretary at least three (3) days prior to the meeting by telephone (805) 688-3008 or by email to wendy@syicsd.com

Any public records which are distributed less than 72 hours prior to this meeting to all, or a majority of all, of the District's Board members in connection with any agenda item (other than closed sessions) will be available for public inspection at the time of such distribution at the District's office located at 1070 Faraday, Santa Ynez, California 93460

**SANTA YNEZ
COMMUNITY SERVICES DISTRICT
STAFF REPORT**

TO: BOARD OF DIRECTORS

PREPARED BY: Jeff Hodge, General Manager

FOR: REGULAR BOARD MEETING

DATE: February 28, 2017

ITEM: Authorize staff to spend money not to exceed \$20,000.00 to repair the broken sewer line at the intersection of Cimarron and Remmington.

SUMMARY: Due to higher than normal flows staff investigated multiple manhole sites to isolate the water intrusion point. District staff determined that there were unusually higher flows in Reach 254 to 240 and after confirming with video, the sewer line has pulled apart. Staff has already notified the property owner. Staff received a quote from RL Johnson to repair the line, however it may require a special dewatering process due to the major influx of water but that can't be determined until the line is exposed.

RECOMMENDATION: Authorize staff to spend money not to exceed \$20,000.00 to repair the broken sewer line.

ATTACHMENTS:
RL Johnson quote



RL Johnson Construction, Inc.

PO Box 2359
Lompoc, CA 93438

Estimate

Date	Estimate No.
2/24/2017	3700

Name/Address
Santa Ynez Community Services Dist. P.O. Box 667 Santa Ynez, CA 93460

Project
114-1 Emergency Sewer Break

Description	Qty	Rate	Total
<p>R.L. Johnson Construction is proposing to fix an emergency sewer repair on Remmington and Cimmeron streets in Santa Ynez. The existing sewer line to be repaired is 8" diameter and approx. 13' deep, it is located along an existing equestrian trail with no obstructions. R.L. Johnson is estimating a 2 day minimum if project runs longer additional prices will be charged at an hourly rate.</p> <p>R.L. Johnson Construction, Inc. is not responsible for the damage of any unmarked utility / sprinkler lines above or below ground; nor the re-growth of vegetation. R.L. Johnson Construction, Inc is not accountable for any additional security or escorts. All permits, soil & water testing are not the responsibility of R.L. Johnson Construction, Inc. Wet, rock &/or hard ground conditions will be charged at a time & materials bases only. All buried items that need to be removed from the site will be at a time & materials basis. Water usage for dust control & compaction will be paid by others. Water for construction use is to a 2 1/2' outlet min. and is to be as close to job site as possible. R.L. Johnson Construction will not be responsible for and traffic loops and/or signals.</p>	1	9,987.00	9,987.00

If you have questions please don't hesitate to call. Thank you.	Total	\$9,987.00
---	--------------	-------------------

Phone #	Fax #	E-mail
805-735-8084	805-736-4369	carli@rljohnsonlompoc.com

